



Essential Safety Measures Requiring Maintenance CITY OF MONASH

10-12 Bogong Avenue, GLEN WAVERLEY

Essential Safety measure:	BCA or other provision to which Essential Safety Measure has been installed and is to operate:	Frequency and type of maintenance required:
Emergency Lighting	BCA Part E4, AS 2293.1	6 monthly to AS 2293.2
Exit Doors	BCA Section D	3 monthly inspections to confirm exit doors are intact, operational and fitted with conforming hardware
Exit signs	BCA Part E4, AS 2293.1	6 monthly to AS 2293.2
Fire Blanket		Annual inspection
Fire extinguishers (portable)	BCA E1.6, AS 2444	6 monthly to AS 1851.1
Fire hose reels	BCA E1.4	6 monthly to AS 1851.2
Fire hydrants	BCA E1.3, AS 2419.1	6 monthly to AS 1851.4
Paths of travel to exits	BCA Section D	3 monthly inspections to confirm travel paths are intact
Smoke alarms	BCA E1.7, G3.8, Vic H101.9, Vic H103 or AS 3786	Monthly to AS 1851.8 (as applicable)



Essential Safety Measures Requiring Maintenance CITY OF MONASH

10-12 Bogong Avenue, GLEN WAVERLEY

Essential Safety measure:	BCA or other provision to which Essential Safety Measure has been installed and is to operate:	Frequency and type of maintenance required:
Emergency Lighting	BCA Part E4, AS 2293.1	6 monthly to AS 2293.2
Exit Doors	BCA Section D	3 monthly inspections to confirm exit doors are intact, operational and fitted with conforming hardware
Exit signs	BCA Part E4, AS 2293.1	6 monthly to AS 2293.2
Fire Blanket		Annual inspection
Fire extinguishers (portable)	BCA E1.6, AS 2444	6 monthly to AS 1851.1
Fire hose reels	BCA E1.4	6 monthly to AS 1851.2
Fire hydrants	BCA E1.3, AS 2419.1	6 monthly to AS 1851.4
Paths of travel to exits	BCA Section D	3 monthly inspections to confirm travel paths are intact
Smoke alarms	BCA E1.7, G3.8, Vic H101.9, Vic H103 or AS 3786	Monthly to AS 1851.8 (as applicable)